

Operator's Report
Kyle and Greg
2-19-2023

Leaks repaired and discovered:

- Main line from spring to A side filters by the south end of the freeway. Temporary repair was done over the weekend, official repair done on Monday January 23. Wycoffs opened for us on a Sunday when they are generally closed to help us get through the weekend.
- Leak repaired on Meter at 81 Madrone drive
- Leak discovered on B line going up Maple Dr.
- Leak discovered at the intersection of School Road and Newton in a valve. It's currently small. We are working on more significant leaks first and funding. This leak may require heavy equipment and funds.
- We discovered 2 leaks at the trailer park. The owner of the trailer park and residents who live in the park came together and got it repaired.

We replaced meter faces at the following addresses:

- 70 Lum
- 192 Weott Heights
- 4 Lum st. trailer park
- 77 sewell
- 438 Newton
- We opened up both filters on A side to inspect the media inside. The media in the first filter needed to be cleaned. We added a new bag of fine anthracite. The media in the second filter looked good so we didn't have to clean or replace it.
- Still on boil water until emergency funding comes through and the springs and filters can be upgraded, or if our test results start meeting requirements. When there is a heavy rain event the turbidity is worse and extra caution should be taken. This is going to take time. Once we have the funding we can start the projects.