

# **Weott CSD's Operator's Report**

**9-10-2025**

**Greg Teasley**

## **Springs/Flow:**

As of today we still have good flow on both A and B lines. I am still working on getting up to the springs which I will have to do after these rains. I also have to make up the parts list to hook up the other spring.

## **Test Results:**

Water quality has been passing state standards.

## **Water Plant:**

It has been working efficiently.

## **Wastewater Plant:**

It is passing tests and there are no new malfunctions. I did meet with Jim An engineer from the CE corps of engineers last week and showed him the operating process of the W.W.T.P. As soon as finances allow, we need to get another pumper truck or 2 to remove some of the sludge that is in the system beyond the solids tank.

## **Lift station:**

Both pumps are working as they should be.

## **Repairs & Leaks**

I replaced the 3 inch meter at the school and also the leaking valve at the water treatment plant. I also had to make a repair to a one inch water distribution line that was damaged during excavation at a property on Weott Heights road. I also replaced a leaking valve in a meter box and fixed a leak on Parish lane.