

Weott CSD's Operator's Report
11-12-2025
Greg Teasley

Springs/Flow:

- As of today we still have good flow on both A and B lines.
- Curren and I are planning a trip across the river as soon as possible.

Test Results:

- Water quality has been passing state standards.

Water Plant:

- It has been working efficiently.
- The problem with the automatic transfer switch for generator power really needs to be addressed ASAP because if the power goes out in the middle of the night or if it goes out and I or Curren are not in town. Then, the water goes through the plant untreated.

Wastewater Plant:

- It is passing tests and there are no new malfunctions

Lift station:

- Both pumps are working as they should be.
- But the counter for the cycles on the lead pump has stopped working. I priced one, and it's gonna be about two or three hundred dollars to replace.

Repairs & Leaks

- After repairing a leak on Parrish lane one of the residence's had very low pressure. I was able to increase the pressure after taking the meter out and pressurizing their plumbing with air to blow any debris that may have dislodged on the initial repair.
- There is also another residence on Parrish that has standing water in their water meter box. Which is being caused by a leak on a line going through a big group of Redwoods. This is not the first time we've had trouble on this line. I think the only way to remedy it is to reroute the line.
- After locating both the water and sewer service connections, I installed a new meter on one of the subdivided parcels on spring street.